

MPC and MCVV Residential Hall Fire Log

| DATE REPORTED | REPORT NUMBER | DATE OCCURRED | TIME OCCURRED | NATURE OF THE FIRE | LOCATION |
|-----------------------|---------------|--|---------------|---|--|
| 1/1/2020 | 202001010334 | 1/1/2020 | 1950 | A dryer fire caused by clogged lint in the vent duct occurred at this location. | Broad and Belvidere Student Apartments 700 W. Broad St. |
| 1/2 - 1/15/2020 | | NO REPORTABLE INFORMATION AT THIS TIME | | | |
| 1/16/2020 | 202001160258 | 1/16/2020 | 1939 | A cooking fire occurred at this location. | Grace and Broad Residence Center 1010 W. Grace St. |
| 1/17 - 1/31/2020 | | NO REPORTABLE INFORMATION AT THIS TIME | | | |
| 2/1/2020 | | NO REPORTABLE INFORMATION AT THIS TIME | | | |
| 2/2/2020 | 202002020039 | 2/2/2020 | 0444 | An unknown subject set fire to a smoke detector at this location. | Rhoads Hall 710 W. Franklin St. |
| 2/3 - 2/29/2020 | | NO REPORTABLE INFORMATION AT THIS TIME | | | |
| 3/1/2020 - Present | | NO REPORTABLE INFORMATION AT THIS TIME | | | |